

AGA CERTIFIED PRODUCT



Certificate Holder: **A.A.P. INDUSTRIES PTY LTD**
ABN/ACN No. (if applicable): **000 402 826**
Manufacturer: **NINGBO HUACHENG VALVE COMPANY LTD**
Agent (if applicable): **N/A**
Type of Component: **MANUAL SHUT-OFF VALVE**
Type 1 MWP: 2500kPa
Temperature Range: 0°C to 60°C

JAS-ANZ



www.jas-anz.org/register

Model No. & Description:
(Refer www.aga.asn.au for more details)

MAXIFLO, appFLO
HC-210
NOMINAL SIZES: 1/4" (8mm), 3/8" (10mm),
1/2" (15mm), 3/4" (20mm), 1" (25mm),
1 1/4" (32mm) 1 1/2" (40mm), 2" (50mm),
2 1/2" (65mm), 3" (80mm) & 4" (100mm)

End Connections: F X F, M X F to ISO 7.Pt 1 & 2
Alternatively 3/4" (20mm) Valves can have
compression and nut and tail end fittings thread forms
comply with ISO 7 Pt 2

Relevant Standard(s): **AS 4617 – 2004**
(Incorporating Amendment 1)

This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

This Certificate is issued on the express conditions that:

- (i) The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- (ii) This Certificate remains the property of the AGA; and
- (iii) The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.



James D Burns

Client Manager

[Signature]

Certificate Authorised

Certificate first issued: **10 June 2000**

Certificate No: **6017**

This copy valid from: **6 March 2017**

Refer specification issue: **07**

Directory Certificate Entry

Components

Manual Shut-Off Valves

Type 1 - Isolating Valves

A.A.P. Industries Pty Ltd

(31 Monro Ave, Kirrawee, 2232 NSW AUSTRALIA Ph: (02) 9521 4433)

Relevant Standard/s:

AS 4617 | 2004 Amdt 1 | Manual Shut-Off Gas Valves | 9/03/2011

MAXIFLO, APPFLO

6017 6.00

Manual Shut-Off Gas Valve - Type 1

kPa Rating

HC-210 NOMINAL SIZES ¼" (8mm), 3/8" (10mm), ½" (15mm),
¾" (20mm), 1" (25mm), 1¼" (32mm) 1½" (40mm), 2" (50mm),
2½" (65mm), 3" (80mm) & 4" (100mm)

2500

Temperature Rating 0 - 60°C

End connections F X F, M X F to ISO 7.Pt 1 & 2.

*Alternatively ¾" (20mm) valves can have compression
and nut and tail end fittings thread forms comply with ISO 7 Pt 2.*

Wednesday, 8 March 2017