



Product Authorisation Certificate

For use in City West Water's Infrastructure Systems

Issued to

AAP Industries Pty Ltd

Authorisation	12/596	Licence No:	SMKP20171
Australian Standard:	AS 2638.2-2006	WSAA Product Specification	WSA PS 260
Other Standards:		Production Authorisation	29 November 2017
		Expiry Date:	

Description of Product

Maxiflo™ Resilient Seated Gate Valve for water supply and pressure sewer applications

1. PN 16, DN 100 to DN 300, FI-FI, Soc-Soc and FI-Soc
2. Flanges to AS/NZS 4087 Figure B5 or AS 2129 Table D
3. ACC for Drinking / Non Drinking Water and CC for Pressure Sewer.



ACC for water supply



CC for pressure sewer

Conditions

1. Where a range of items or sizes are involved, this Authorisation applies only to those items or sizes listed in the MRWA Products Web Portal <http://www.mrwa.com.au/Pages/Home.aspx>.
2. This Authorisation does not refer to the effectiveness of the product and no claim shall be made through advertising, promotion or in any other way that the above products have been authorised or tested by CWW in other than the terms of this authorisation.
5. AAP Industries Pty Ltd shall be responsible for assuring the quality of approved products that are supplied by AAP Industries Pty Ltd to the market. Where the approved products or parts thereof are manufactured or assembled by a third party, AAP Industries Pty Ltd shall employ systematic procedures to verify product conformance.
6. The product shall be manufactured under a third party certified Quality Assurance System. All products shall be identified with the manufacturers name or trade mark.

3. The items described above are authorised for use in CWW Infrastructure systems, in accordance with the design and installation practices as detailed or referenced in the:
 - § Melbourne Retail Water Agency (MRWA) Edition of the Water Services Association of Australia (WSAA) Water Supply Code of Australia WSA 03:2012 Version 3.1;
 - § WSAA's Sewage Pumping Station Code of Australia WSA 04-2005 Version 2.1;
 - § WSAA's Pressure Sewerage Code of Australia WSA 07-2007 Version 1.1;
 - § CWW's supplement to the code; and
 - § Other installation recommendations of the Manufacturer.
4. This approval is valid for five years from the issue date of this certificate. Renewals of approval should be sought three months prior to approval expiry.
7. The products shall demonstrate satisfactory performance when installed in CWW Infrastructure system.
8. CWW shall be notified in writing if:
 - § The third party certification is withdrawn, suspended or changed;
 - § Any change of the certification agency occurs;
 - § There are any changes to product design, materials, model numbers etc; or
 - § The products are to be withdrawn from sale.
9. The products may be subjected to random quality control checks for which a charge may apply. Compliance with new Standards as they are replaced will need to be demonstrated.
10. CWW reserves the right to request additional information and / or evidence of product suitability add or vary to the conditions set out above, or if necessary, modify or withdraw the authorisation at any time.

Signed: 

Robert Jagger
Manager Standards

This Certificate is issued without alteration or erasure.

Date: 30 November 2012